



PERMIT NUMBER

w #42006

WATER WELL AND PUMP RECORD

Completion is required under authority of Part 127 Act 368 PA 1978.
Failure to comply is a misdemeanor.

WSSN & SOURCE ID/WELL NUMBER

TAX NUMBER
04-002-002-86-00

LATITUDE
42.52011

LONGITUDE
85.33911

COUNTY
Barry

TOWNSHIP
Hastings

DISTANCE & DIRECTION FROM ROAD INTERSECTION
1/4 mile south of Smith Road on the east side of Jones Road

WELL STREET ADDRESS, CITY/ZIP
2222 Jones Road
Hastings, MI 48888

FRACTION NE 1/4	SW 1/4	SW 1/4	SECTION 13	TOWN NO. 8N	RANGE NO. 16W
WELL OWNER John Doe ADDRESS 2222 Jones Road CITY/ZIP Hastings, MI 48888					
Owner Address Same As Well Address? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					

DRILLING METHOD Cable Tool Rotary Auger/Bored
 Hollow Rod Jetted Other

PUMP Not Installed Pump Installation Only
Manufacturer FE Myers

WELL DEPTH 84 ft.
WELL USE Household Type I Public
 Test Well Irrigation Type II Public
 Heat Pump Industrial Type III Public
 Other

Pump Type Submersible Jet Other
Model Number 12-50D-10 HP .5 Volts
Pump Capacity 10 G.P.M. Drawdown Seal Installed
Length of Drop Pipe 60 ft. Diameter of Drop Pipe 1 in.

DATE COMPLETED 01 | 14 | 06
WELL TYPE New Replacement Dry Hole

PRESSURE TANK Not Installed Buried
Type Diaphragm/Bladder Other

CASING Steel-Black Plastic Steel-Galvanized
 Welded Threaded Other
Diameter 5 in. to 80 ft. depth 21 SDR
_____ in. to _____ ft. depth _____ SDR

Manufacturer Well-Xtrol Model WX202
Total Tank Capacity 20 gal. Pressure Relief Valve Installed

BOREHOLE
Diameter 8.5 in. to 84 ft. depth
_____ in. to _____ ft. depth
Height _____ Casing Fittings _____
Above/Below Surface 1 ft. Drive Shoe Shale Packer

Formation Description	Thickness of Stratum	Depth to Bottom of Stratum
sand	10	10
blue clay	14	24
sand and gravel	40	64
gray clay and stones	7	71
medium sand water bearing	13	84

STATIC WATER LEVEL
20 ft. Below Land Surface Flowing

PUMPING LEVEL (Below Land Surface)
25 ft. After 2 hrs. Pumping at 40 G.P.M.
 Air Bailer Plunger Test Pump

SCREEN Not Installed Filter-Packed
Material Type stainless wirewrapped Diameter 4 in.
Slot 12 Length 4 ft.
Set Between 80 ft. and 84 ft.

FITTINGS Neoprene Packer Bremer Check
BLANK above 1 ft. Other _____

WELL GROUTED Yes No From 0 ft. to 80 ft.
 Neat Cement Bentonite Slurry Bentonite Dry Granular
 Other _____ No. of Bags 9 Additives _____

WELLHEAD COMPLETION Pitless Adapter 12 in. Above Grade
 Basement Offset Well House

NEAREST SOURCE OF POSSIBLE CONTAMINATION
Type septic tank Distance 67 ft. Direction north
Type fuel tank Distance 350 ft. Direction west

ABANDONED WELL PLUGGED Yes No
Casing Diameter 2 in. Depth 50 ft.

PLUGGING MATERIAL Neat Cement Bentonite Slurry
 Cement/Bentonite Slurry Concrete Grout Bentonite Chips
Number of Bags 3 Casing Removed? Yes No

DRILLING MACHINE OPERATOR Employee Subcontractor
Name Frank Miller

PUMP INSTALLER (If different from drilling machine operator.)
Name George Taylor

REMARKS
unable to remove obstructions from old well

EXAMPLE

USE 2ND SHEET IF NECESSARY

WATER WELL CONTRACTOR'S CERTIFICATION
This well was drilled under my supervision and this report is true to the best of my knowledge and belief.

Wirth Well Drilling 3434
Registered Business Name Registration No.
Address 5555 Star Road
City/State/Zip Grand Ledge, MI 47777
Robert Wirth 2-28-06
Signature of Registered Contractor Date

ATTENTION WELL OWNER: FILE WITH DEED